



Public Health Engineering Department

Government of West Bengal

Tender: NIQ-13 OF 2025-2026 OF AE-II/AMD

1. General Information

Type	NIQ	Category	Works	Mode	OFFLINE	Method	Open Tender
District	PASCHIM BARDDHAMAN		Inviting Authority		Executive Engineer, Asansol Mechanical Division		
Tender Reference	NIQ-13 OF 2025-2026 OF AE-II/AMD	Estimate Put to Tender		Memo No	1716/AE-II/AMD	Memo Date	10-10-2025
e Tender Id		Description	ELECTRO-MECHANICAL TYPE OF WORKS				
Estimated Work Value		-					

2. EMD (Earnest Money Deposit) Details

Exempted?	No	Fee Type		Payable To		Payable At	
-----------	----	----------	--	------------	--	------------	--

3. Critical Dates

Tender Publish Date	10-10-2025 05:00 PM	Sale/Submission Start Date	
Download Start Date		Sale/Download End Date	03-11-2025 03:00 PM
Last Date of Application	31-10-2025 02:00 PM	Last Date of Permission	31-10-2025 02:00 PM
Last Date of Submission	03-11-2025 03:00 PM	Tech Bid Opening Date	
Fin Bid Opening Date	03-11-2025 03:30 PM	Tech Bid Uploading Date Time	
Uploading Bid Date Time			

4. Pre-bid Meeting Details

Date		Venue		Address	
------	--	-------	--	---------	--

5. Work Details

Sl No	Description	Estimated Cost (Rs.)	Completion Time	EMD (Rs.)
1	Jungle cutting & cleaning compound premises at Various Pump House Premises under Block-Kanksa, Paschim Bardhaman, under Asansol Mechanical Division, PHE Dte	Rate Quoted	10 days	N.A.
2	Supply delivery and Installation of chlorine machine spare parts at various pump house (Rajkusum, Birudiha, Dandeswar, Banagram, Napara, Rupganj, Gopalpur etc.) of Block- Kanksa , Dist- Paschim Bardhaman, under Asansol Mechanical Division, P.H.E. Dte.	Rate Quoted	10 days	N.A.
3	Electrical wiring & fitting, fixing of lighting luminaries for Quarter Complex with Chlorine Room at Searsole Boosting Station under RCFA Part-II Water	Rate Quoted	10 days	N.A.

	Supply Scheme.			
4	Repairing & Overhauling of 11KV/0.433KV, 500 KVA, indoor type transformer at Pansuli Head works site under RCFA Part-III(Zone-I) Water Supply Scheme.	Rate Quoted	10 days	N.A.
5	Cleaning, Servicing of 11KV/0.433KV, 315 KVA, indoor type transformer at Ramnagar Pump House under RCFA Part-III(Zone-II) Water Supply Scheme.	Rate Quoted	10 days	N.A.
6	Earthing arrangement at Kalajharia Sub-Station for 1250 KVA Transformer & VCB under RCFA Part-II water supply scheme.	Rate Quoted	10 days	N.A.

6. Attachments

Sl No	File Name
1	NIQ13.pdf
2	Schedule 13.pdf